

Test Report

Oil-refill-joint 12KV additional type test-150mm² - 3C/GX

Report Nr.: 17759

Test specifications

<i>Test object</i>	: 12kV Oil-refill-joint
<i>Type</i>	: LoviSil M105 with M85 inner shell
<i>U₀ / U (U_m)</i>	: 6 / 10 (12) kV
<i>Rated cross-section range</i>	: Three core PILC 150mm ² Three core / 3x single core Poly 150mm ²
<i>Manufacturer</i>	: Lovink Enertech b.v.
<i>Test period</i>	: 17-07-2017 / 21-07-2017
<i>Test location</i>	: Terborg, The Netherlands

Relevant Normative Documents

NEN-EN-IEC 61442:2005
CENELEC HD 629.2 S2:2006

Test performed

Type test following CENELEC HD 629.2 S2:2006, Table 9

Test result

Author:
Bjorn Zieverink
Test engineer

Accepted:
Dennis Bergsma
Product Development Manager

Terborg, 14-08-2017